

# Flexibility costs under high variable renewable energy generation: *the Chilean case*

S. Mocarquer, R. Quinteros, S. Binato, M. V. F. Pereira

2018 IEEE GENERAL MEETING

Portland, August 2018



# Overview

- Objectives of the Analysis
- Chilean Market Overview
- Methodology
- Results
- Conclusions

# Objectives

- Quantify the effects of massive VRE<sup>1</sup> insertion in the operation of the electric system with focus on ‘Flexibility Costs’
- Provide valuable inputs for the regulatory discussion in Chile
- The study was commissioned by the Chilean Generators Association (AG)



Generadoras de Chile





- Independent analysis based on public information

# Chilean Market Overview


## Key information 2017

<b>Renewable generation</b>	15% (excluding large hydro)
<b>Peak demand</b>	10,363 MW
<b>Energy Sales</b>	49% regulated, 51% un-regulated
<b>Transmission lines</b>	32,100 km
<b>GDP per capita (PPP)</b>	US\$ 24,085



Source: Annual Energetic Report CEN, January 2018. Installed Capacity SEN, Anuario CNE 2017. GDP, The World Bank.

# Consulting Team




- Consulting firm founded in 2013 by executives from the electricity sector, in Santiago - Chile, to support investors and stakeholders in decision-making in the energy sector.
- Wide range of services taking advantage of extensive experience and high degree of specialization;
  - Market and regulation analysis
  - Business strategy
  - Due diligence for transactions
  - Business development
- Provider of analytic tools and consultancy (economic, regulatory and financial studies) in electricity and natural gas since 1987, based in Rio de Janeiro – Brazil.
- Team of 54 specialists (17 PhDs, 31 MSc) in engineering, optimization, energy, statistics, finance, regulation, IT and environmental analysis.
- In more than 70 countries on all continents.

[www.morayenergy.com](http://www.morayenergy.com)

[www.psr-inc.com](http://www.psr-inc.com)

# Methodology of the study

- The aim was to estimate the flexibility costs associated with different VRE (solar-wind) expansion scenarios




# Modeling Tools: PSR Core planning system




PSR Cloud

## ePSR: Information management environment



# Scenario Definition

- VRE insertion level was driven by investment costs and demand scenario



Scenario coding: D*X*C*Y* – Plan with demand scenario *X* and investment costs *Y*

– *X*: *A* (high demand), *M* (average), *B* (low)


– *Y*: *A* (high price); *M* (average); *B* (low)



# Flexibility

- Flexibility → ability of the system to efficiently respond to supply and demand imbalances
- Massive insertion of VRE → greater challenges in system operation require system flexibility

Wind and Solar Generation [GWh]



## Sources of Flexibility

- Generation technologies ← focus of the study
- Demand response
- Storage technologies
- Interconnections

# Flexibility Cost Components

- The following flexibility costs were evaluated:

Type of Cost	Components	Function
Direct Start Up Costs	Fuel and emission costs	$f(\#Start\ Cycles)$
Indirect Start Up Costs	Capex and maintenance	$f(\#Start\ Cycles)$
Ramp Up/Down Cost	Capex and maintenance	$f(\#Ramp\ Cycles)$
Efficiency Cost	Fuel and emissions	$f(Dispatch)$
Opportunity Costs	Lost variable margin	$f(Dispatch\ and\ Spot\ Price)$


- Cost functions<sup>1</sup> were applied to output variables obtained from the simulations
- Ex-post* analysis to assess unrecovered costs under current regulation

Note: (1) The functions related to the start up and ramp up/down costs have been estimated using approximations based on international sources (Power Plant Cycling Costs, NREL, 2012)

# Criteria for operational reserve


- Challenge to incorporate VRE effect to current methodology in use in Chile

➤  $R = f(D, G, VRE)$



# VRE Reserve ( $R_{VRE}$ )

- Required reserve to account for the uncertainty associated with the forecast error of VRE generation from the simulated series:




$$R_{VRE}^* = \lambda \times E(R) + (1 - \lambda) \times CVaR_{90\%}(R)$$

- With this type of risk criterion,  $\lambda=0.8$  represents a reasonable compromise between reliability and cost

# Wind – Solar Complementarity


- The complementarity of the wind and solar generation is captured in the optimized generation expansion considering hourly profiles



# Main Results: Generation Expansion

- Wind and solar technologies grow between 9.000 and 16.000 MW by 2030 (investment potential between US\$ 8.000 and 18.000+ millions)


VRE Expansion 2018-2030 (GW)



- Reserve expansion is identified in the North of Chile (200 – 1.000 MW)

# Main Results: Generation by Technology (Median Hydrology - DMCM)


- VRE generation share of 42% by 2030



- Including hydro, renewables account for 75% of energy generation by 2030

# Main Results: Generation by Technology (Dry Hydrology – DMCM)

- Thermoelectricity is still relevant by 2030 under dry hydrology (33% share)




- No decommissioning of coal fired power plants was considered




# Main Results: Transmission Expansion

- Relevant capacity expansion is needed at 500 kV level by 2025
- Expansion plan proposed by the Government includes a longer 500 kV HVDC line between Kimal and Polpaico (US\$1,8 billion)



# Main Results: Daily Dispatch – 2021


- The reservoirs and thermoelectricity will provide flexibility in an increasing manner
  - Hydro Dam: Daily storage (solar hours)
  - Coal: Ramping/minimum operation
  - CCGT: Cycling



Note: Median Hydrology - DMCM

# Main Results: Daily Dispatch – 2025


- The reservoirs and thermoelectricity will provide flexibility in an increasing manner
  - Hydro Dam: Daily storage (solar hours)
  - Coal: Ramping/minimum operation
  - CCGT: Cycling



Note: Median Hydrology - DMCM

# Main Results: Daily Dispatch – 2030


- The reservoirs and thermoelectricity will provide flexibility in an increasing manner
  - Hydro Dam: Daily storage (solar hours)
  - Coal: Ramping/minimum operation
  - CCGT: Cycling



Note: Median Hydrology - DMCM

# Main Results: Marginal Cost

- Fluctuation of intraday marginal cost increases over time leading to potential collapse during solar hours by 2030




- The minimum cost expansion requires long-term signals (contracts)
  - Pure short-term marginal cost signals (in solar hours) may be insufficient to trigger investment


# Main Results: Reserve Requirements

- Increasing reserve requirements in certain periods of the day
- Dynamic probabilistic reserve determination criteria will be key to address high VRE insertion levels

Minimum Reserve SING (DACB)




Minimum Reserve SIC (DACB)




# Main Results: Flexibility – 2021

- Residual generation<sup>1</sup>: the Chilean ‘Duck Curve’



Case	Max Increase		Max Distribution	
	MW/min	Between Hours	MW/min	Between Hours
DACB	19,8	18-19	-18,2	21-22
DMCM	19,3	18-19	-17,8	21-22
DBCA	18,8	18-19	-17,4	21-22




Case	Max Increase		Max Distribution	
	MW/min	Between Hours	MW/min	Between Hours
DACB	15,7	18-19	-10,1	20-21
DMCM	15,8	18-19	-9,9	20-21
DBCA	15,9	18-19	-9,7	20-21


Note: (1) Discounting VRE generation. Median Hydrology - DMCM

# Main Results: Flexibility – 2025

- Residual generation<sup>1</sup>: the Chilean ‘Duck Curve’



Case	Max Increase		Max Distribution	
	MW/min	Between Hours	MW/min	Between Hours
DACB	38,7	20-21	-61,2	7-8
DMCM	29,0	19-20	-46,3	7-8
DBCA	23,9	18-19	-35,4	7-8




Case	Max Increase		Max Distribution	
	MW/min	Between Hours	MW/min	Between Hours
DACB	63,2	18-19	-36,0	8-9
DMCM	49,6	18-19	-29,6	8-9
DBCA	38,7	18-19	-22,4	8-9

Note: (1) Discounting VRE generation. Median Hydrology - DMCM




# Main Results: Flexibility – 2030

- Residual generation<sup>1</sup>: the Chilean ‘Duck Curve’



Case	Max Increase		Max Distribution	
	MW/min	Between Hours	MW/min	Between Hours
DACB	63,7	20-21	-92,6	7-8
DMCM	53,0	20-21	-81,5	7-8
DBCA	39,1	20-21	-62,3	7-8



Case	Max Increase		Max Distribution	
	MW/min	Between Hours	MW/min	Between Hours
DACB	94,0	18-19	-66,3	8-9
DMCM	84,9	18-19	-60,8	8-9
DBCA	68,7	18-19	-47,9	8-9



Note: (1) Discounting VRE generation. Median Hydrology - DMCM

# Main Results: Thermoelectricty Cycling



## Coal Plant:

## CCGT:



2021



2025




2030



Note: Results corresponds to April, DMCM scenario.


# Main Results: Flexibility Costs

- Thermoelectric generators will incur in increasing flexibility costs
  - US\$150 to 350 millions per year in 2030 (mostly driven by start up/down cycles)



# Conclusions

- Unitary operation costs will be reduced between 11% and 20% by 2030
- Flexibility costs could reach up to US \$ 350 millions by 2030




- Flexibility costs must be addressed in the regulation so that the potential VRE expansion can be achieved in an efficient manner

# Further reading

- Full report and additional presentations can be downloaded from our website:

<http://www.morayenergy.com/>



# Flexibility costs under high variable renewable energy generation: *the Chilean case*

S. Mocarquer, R. Quinteros, S. Binato, M. V. F. Pereira

2018 IEEE GENERAL MEETING

Portland, August 2018



# Disruptive factors

- The analysis presented is subject to the following uncertainty factors:
  - Changes in the CO<sub>2</sub> tax level and treatment
  - Corporate decarbonization policies
  - Effect of climate change on hydrology
  - Greater competitiveness of storage systems
  - International interconnections development (electricity and gas)